

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

|  |   |          |
|--|---|----------|
| THE APPLICATION OF DEWITT WATER DISTRICT     | ) |          |
| FOR A DEVIATION FROM THE REQUIREMENTS OF     | ) | CASE NO. |
| 807 KAR 5:066, SECTION 4(4), REGARDING WATER | ) | 98-115   |
| STORAGE                                      | ) |          |

O R D E R

On March 3, 1998, the Dewitt Water District ("Dewitt District") applied for permission to deviate from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Dewitt District states in its application that it purchases an average of 3,245,000 gallons per month from East Knox County Water District and Corbin City Utilities Commission. Dewitt District also states that its Road Fork Project will provide a storage tank to bring the system into compliance with Commission regulations.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Dewitt District is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Dewitt District should be given until July 1, 1999 to comply with 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:

1. Dewitt District is given until July 1, 1999 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Dewitt District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1999.

Done at Frankfort, Kentucky, this 27th day of April, 1998.


PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director